

Jefferson School District – District Office
Lead Testing Results Summary 10/31/2016

AB - Abandon the Source
 AL - Acceptable Level
 BW - Bottled Water supply
 CS - Cut Supply to water source
 CWO - Cold Water Only use

LFM - Lead-Free Materials used
 NTR - No Testing Required
 M/AF – Manually/Automatic Flush
 RAC - Routine Aerator Cleaning
 RF - Replace Faucet

RP - Replace supply Pipe
 RTF - Retest with Flush period
 RW - Run Water supply before use
 Sign - Signage restricting consumption

Date Collected	Lab #	Sample Site	Sample Site Descriptor	Lead Test Results, (Action Level of 20 ppb)	Action Taken
9/29/2016	20160929-21	1 DO	Sink in Sec. office	ND @ 1	AL
9/29/2016	20160929-24	4 DO	Sink in Breakroom (west)	1.1	AL
9/29/2016	20160929-26	6DO	Sink in Board room	ND @ 1	AL
9/29/2016	20160929-27	7 DO	Sink – Boardroom	2.6	AL
9/29/2016	20160929-25	14 DO	Filtered water spout	ND @ 1	AL