

Jefferson School District - Jefferson Elementary School

Lead Testing Results Summary 10/31/2016

AB - Abandon the Source
 AL - Acceptable Level
 BW - Bottled Water supply
 CS - Cut Supply to water source
 CWO - Cold Water Only use

LFM - Lead-Free Materials used
 NTR - No Testing Required
 M/AF - Manually/Automatic Flush
 RAC - Routine Aerator Cleaning
 RF - Replace Faucet

RP - Replace supply Pipe
 RTF - Retest with Flush period
 RW - Run Water supply before use
 Sign - Signage restricting consumption

Date Collected	Lab #	Sample Site	Sample Site Descriptor	Lead Test Results, (Action level of 20 ppb)	Action Taken
9/29/2016	20160929-102	4E	Fountain by Room 10	7.2	AL
9/29/2016	20160929-104	6E	Health Room sink	ND @ 1	AL
9/29/2016	20160929-105	7E	Sink in secretaries office	54.2	RTF
9/29/2016	20160929-109	11E	Fountain across Lib - west hall	7.6	AL
9/29/2016	20160929-114	17E	Fountain-West hall by Rm 17	1	AL
9/29/2016	20160929-115	18E	Fountain-East hall by Rm 17	2.4	AL
9/29/2016	20160929-117	20E	Fountain-Gym	ND @ 1	AL
9/29/2016	20160929-118	21E	Sink – teachers lounge	ND @ 1	AL
9/29/2016	20160929-119	22E	Filtered tap-teachers lounge	ND @ 1	AL
9/29/2016	20160929-120	23E	Hand sink-kitchen	ND @ 1	AL
9/29/2016	20160929-121	24E	South sink - faucet	5.2	AL
9/29/2016	20160929-122	25E	North sink - faucet	3.5	AL
9/29/2016	20160929-123	26E	Spray wand – dish room	1.5	AL
9/29/2016	20160929-168	34E	Fountain Rm 1	9.5	AL
9/29/2016	20160929-167	37E	Fountain- Rm 2	14.1	AL
9/29/2016	20160929-166	40E	Fountain Rm 3	2.1	AL
9/29/2016	20160929-165	43E	Fountain Rm 4	1.1	AL
9/29/2016	20160929-164	46E	Fountain Rm 5	7	AL
9/29/2016	20160929-163	53E	Fountain Rm 6	5.3	AL
9/29/2016	20160929-162	56E	Fountain Rm 7	1.3	AL
9/29/2016	20160929-161	59E	Fountain Rm 8	2.6	AL
9/29/2016	20160929-160	62E	Fountain Rm 9	1.5	AL
9/29/2016	20160929-146	69E	Fountain Rm 20	3	AL
9/29/2016	20160929-148	71E	Fountain Rm 21	2.6	AL
9/29/2016	20160929-188	75E	Fountain Rm 23	6.4	AL
9/29/2016	20160929-156	80E	Fountain Rm 24	4.2	AL
9/29/2016	20160929-158	82E	Fountain Rm 25	3.2	AL