

Jefferson School District – Jefferson High School

Lead Testing Results Summary 10/31/2016

AB - Abandon the Source
 AL - Acceptable Level
 BW - Bottled Water supply
 CS - Cut Supply to water source
 CWO - Cold Water Only use

LFM - Lead-Free Materials used
 NTR - No Testing Required
 M/AF – Manually/Automatic Flush
 RAC - Routine Aerator Cleaning
 RF - Replace Faucet

RP - Replace supply Pipe
 RTF - Retest with Flush period
 RW - Run Water supply before use
 Sign - Signage restricting consumption

Date Collected	Lab #	Sample Site	Sample Site Descriptor	Lead Test Results, (Action Level of 20 ppb)	Action Taken
9/22/2016	20160922-14	16H	North Sink-Staff RR	74.6	RTF
9/22/2016	20160922-15	17H	South Sink – staff RR	9.6	AL
9/22/2016	20160922-17	19H	West Sink – Home Ec Rm	30.1	RTF
9/22/2016	20160922-18	20H	Sink –West #2 (heading east)	ND @ 1	AL
9/22/2016	20160922-19	21H	Sink-Ec Room #3	18.4	AL
9/22/2016	20160922-20	22H	Sink-Ec Northeast	6.7	AL
9/22/2016	20160922-21	23H	Sink Ec South	10.6	AL
9/22/2016	20160922-23	26H	Sink-Kitchen Veggie south	11.2	AL
9/22/2016	20160922-24	28H	Kitchen-steam Kettle	ND @ 1	AL
9/22/2016	20160922-25	29H	Sink-kitchen: Hand wash	1.6	AL
9/22/2016	20160922-26	30H	Sink-kitchen eye wash	9	AL
9/22/2016	20160922-27	31H	Sink-Kitchen wand by Dishwasher	4.3	AL
9/22/2016	20160922-28	32H	Water fountain-commons	ND @ 1	AL
9/22/2016	20160922-38	43H	Auto shop-fountain	26.7	RTF
9/22/2016	20160922-40	45H	Fountain-Metal Shop	7.8	AL
9/22/2016	20160922-45	51H	Sink-main office West	14.8	AL
9/22/2016	20160922-46	52H	Sink-main office east	28	RTF
9/22/2016	20160922-65	72H	Fountain by center RR	ND @ 1	AL
9/22/2016	20160922-66	74H	Fountain-Freshmen hall	ND @ 1	AL
9/22/2016	20160922-67	75H	Sink-Concessions Fresh hall	48.8	RTF
9/22/2016	20160922-72	80H	Sink-teacher lounge	ND @ 1.	AL
9/22/2016	20160922-76	85H	Sink-ice room	12.1	AL
9/22/2016	20160922-77	86H	Ice machine	1.6	AL
9/22/2016	20160922-78	89H	Fountain-girls locker room	2	AL
9/22/2016	20160922-81	92H	Boys baseball fountain	2.7	AL
9/22/2016	20160922-84	95H	Outside grandstand faucet	4.9	AL