

**Jefferson School District – Jefferson Middle School**

**Lead Testing Results Summary 10/31/2016**

AB - Abandon the Source  
 AL - Acceptable Level  
 BW - Bottled Water supply  
 CS - Cut Supply to water source  
 CWO - Cold Water Only use

LFM - Lead-Free Materials used  
 NTR - No Testing Required  
 M/AF – Manually/Automatic Flush  
 RAC - Routine Aerator Cleaning  
 RF - Replace Faucet

RP - Replace supply Pipe  
 RTF - Retest with Flush period  
 RW - Run Water supply before use  
 Sign - Signage restricting consumption

<b>Date Collected</b>	<b>Lab #</b>	<b>Sample Site</b>	<b>Sample Site Descriptor</b>	<b>Lead Test Results, (Action Level of 20 ppb)</b>	<b>Action Taken</b>
9/29/2016	20160929-87	5M	NW sink - staff room	3.4	AL
9/29/2016	20160929-88	6M	North middle sink-staff room	9.3	AL
9/29/2016	20160929-89	7M	Filtered water faucet-staffrm	10.9	AL
9/29/2016	20160929-90	8M	NE sink-staff room	4.5	AL
9/29/2016	20160929-91	9M	SW sink-staff room	ND @ 1	AL
9/29/2016	20160929-92	10M	SE sink-staff room	1.7	AL
9/29/2016	20160929-94	12M	Sink-Main office health room	ND @ 1	AL
9/29/2016	20160929-95	13M	Fountain by staff room	ND @ 1	AL
9/29/2016	20160929-56	14M	Fountain-8th girls bathroom	3.9	AL
		17M	Fountain-6th girls bathroom	Currently Testing	
9/29/2016	20160929-69	30M	Fountain-6th boys bathroom	3.9	AL
9/29/2016	20160929-71	35M	Fountain - Café	14.7	AL
9/29/2016	20160929-73	37M	Kitchen wand pre-dishwasher	ND @ 1	AL
9/29/2016	20160929-74	38M	Kitchen wand post-dishwasher	14.5	AL
9/29/2016	20160929-75	39M	Kitchen faucet S by exit door	21.4	RTF
9/29/2016	20160929-77	41M	Fountain-Gym by Girls RR	41.6	RTF
9/29/2016	20160929-80	46M	Fountain in girls shower rm	4.2	AL
9/29/2016	20160929-96	53M	Fountain-boys shower rm	1.6	AL